



Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, 3RD FLOOR, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.777.9587

[HTTP://DPP.VI.GOV](http://DPP.VI.GOV)



May 12, 2016

AMENDMENT #1 IFB006PNRT16 (C) Qualified contractors to furnish all labor, tools, equipment, machinery and supply for the Repair to the Elaine Ione Sprauve Public Library, Cruz Bay on St. John Virgin Islands.

INSERT: *Questions and Answers*

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT WITH THEIR BID PROPOSAL.

QUESTIONS & ANSWERS:

IFB006PNRT16(C), Repair to the Elaine Ione Sprauve Library

1. Question: Item No. 03 on the bid sheet. Should the removal of oxidation and repainting of shutter hardware be done in place, or should the shutter hardware be removed from the shutters to perform the repairs?

Answer: It is the choice of the Contractor whether the removal of oxidation and repainting of shutter hardware is done in place or not.

2. Question: Item No. 13 on the bid sheet references a drawing for ADA bathroom renovation. No such drawing was provided.

Answer: Remove item No. 13 from construction document.

3. Question: Bid sheet items 15 & 16 call for No. 3 bars on 12" on center each way for the concrete slab, but the drawing shows 6x6 welded wire mesh. Which is correct?

Answer: 6 x 6-6/6 welded wire mesh shall be used in the concrete slab and not No. 3 bars at 12" o.c.